

**PROFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE.**

No. 490

Date: 30/7/2025

It is certified that an inspection team headed by Er. Vikram Singh Junior Engineer from Water Supply & Sanitation Sub Division, Jalandhar inspected AGI Global School, at Urbana by AGI Jalandhar Heights-2, Pholriwal Jalandhar Punjab 144022 on 24-07-2025 and on the basis of water test report bearing no RE42526/223 dated 30/7/25 DWTLJAL certified that The AGI Global School, at Urbana by AGI Jalandhar Heights-2, Pholriwal Jalandhar Punjab 144022 has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus is satisfactory.

The above valid for a period of **6 Months.**

Signature with Seal:  Sub Divisional Engineer
Name : Er. Chetan Saini W/S & Sanitation
Designation : Sub Divisional Engineer Sub Division Shankot

To
AGI Global School
66 Ft Road, inside Jalandhar Heights-2
Jalandhar

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com

To,

AGI Global School, Jalandhar.
Distt. Jalandhar.

No.: DWTJAL/2526/00223 Dated : 30/07/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 483 Dated: 23/07/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/07/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Jalandhar

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Jalandhar

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com

To,

AGI Global School, Jalandhar.
Distt. Jalandhar.

No.: DWTJAL/2526/00223 Dated : 30/07/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 483 Dated: 23/07/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/07/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Jalandhar

D/A : Test Report



**Authorized Signatory
For, District water Testing Laboratory
Jalandhar**

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtl@jalandhar@gmail.com



TC-14420

TEST REPORT

Name & Address of Customer : AGI Global School, Jalandhar. Distt. Jalandhar.		Customer Reference No.	No : 483 Dated : 23/07/2025
		Sample Submitted by	Sh. Vikram Singh (J.E.)
		Date of Sample Receipt	29/07/2025
		Analysis Starting Date	29/07/2025
		Analysis completion Date	30/07/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC14420250000434F	Sample Type :	Water
Test Report No.:	DWTJAL/2526/00223	Date of Issue :	30/07/2025
Registration no.:	DWTJAL/REG2526/00674	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	AGI Global School, Jalandhar, 66 Feet Road, Inside Jalandhar Heights 2, Jalandhar.(P/Sub.) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Jalandhar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.59@24°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	452.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1.2	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	338.3	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	301.84	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	64.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	34.29	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	50.53	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Amandeep Singh
Chemist/Analyst
Authorized Signatory
For, District water Testing Laboratory
Jalandhar

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com



TC-14420

TEST REPORT

Name & Address of Customer : AGI Global School, Jalandhar. Distt. Jalandhar.			Customer Reference No.		No : 483 Dated : 23/07/2025	
			Sample Submitted by		Sh. Vikram Singh (J.E.)	
			Date of Sample Receipt		29/07/2025	
			Analysis Starting Date		29/07/2025	
			Analysis completion Date		30/07/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:		TC144202500000434F	Sample Type :		Water	
Test Report No.:		DWTJAL/2526/00223	Date of Issue :		30/07/2025	
Registration no.:		DWTJAL/REG2526/00674	Condition of Sample :		Unsealed	
Collection Point:		Private Submersible	Quantity/Type of Bottle:		1000 ml / Amber Coloured Sample Bottle - 500 mL.	
Scheme/Source:		Not Mentioned(Not Mentioned)	Location/Depth :		AGI Global School, Jalandhar, 66 Feet Road, Inside Jalandhar Heights 2, Jalandhar.(P/Sub.) / NA	
Village :		Not Mentioned	Habitation :		Not Mentioned	
Block:		Not Mentioned	District :		Jalandhar	
Latitude :		Not Mentioned	Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.59@24°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	452.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1.2	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	338.3	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	301.84	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	64.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	34.29	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	50.53	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Amandeep Singh
Chemist/Analyst
Authorized Signatory
For, District water Testing Laboratory
Jalandhar

End of the Test Report